

DEPARTMENT OF ENVIRONMENTAL PROTECTION & SUSTAINABILITY

Interoffice Memo

TO: Glen A Keller, P.E., Chief  
Sewer Design Section  
Department of Public Works

FROM: Thomas L. Vidmar, P.E.        */signed/*  
Deputy Director, EPS

DATE: June 11, 2013

SUBJECT: Boxwood Lane Sewer Extension  
Storm Water Management Variance  
Loch Raven Watershed  
**EPS Project ID: A107910**  
**Tracking Number: 03-13-1651**

This office has reviewed the information submitted and finds that a storm water management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a storm water management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of this article. This project is for the installation of a sewer line by cut and cover. The existing cover conditions will be reestablished once the 8" PVC is installed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Lamar A. Williams of my staff at 410-887-3768 should you have any questions.

TLV:jcm