

Stormwater Engineering

410-887-3768
FAX 410-887-4804

March 20, 2013

Kristy M. Bischoff, P.E.
Daft, McCune, Walker, Inc.
200 East Pennsylvania Avenue
Towson, MD 21286

RE: 8814 COWENTON AVENUE
Storm Water Management Variance
Bird River Watershed
EPS Project I.D. D000063
EPS Tracking Number: 05-13-1600

Dear Ms. Bischoff:

This office has reviewed the information submitted and finds that a storm water management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a storm water management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of this article. This project is for a temporary stockpile. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Lamar A. Williams of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Thomas L. Vidmar, P.E., Deputy Director
Department of Environmental Protection
& Sustainability

TLV:jcm