

Stormwater Engineering

410-887-3768
FAX 410-887-4804

April 2, 2013

Kevin Walker, P.E.
Phoenix Engineering
309 International Circle #130
Hunt Valley, MD 21030

RE: 42" TOWSON WATER TRANSMISSION MAIN
Storm Water Management Variance
Back River Watershed
EPS Project I.D. M130032
EPS Tracking Number: 05-13-1606

Dear Mr. Walker

This office has reviewed the information submitted and finds that a storm water management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a storm water management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of this article. This project is for the installation of a new 42 inch water main by cut and cover. The existing cover conditions will be reestablished once the 42 inch pipe is installed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Lamar A. Williams of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Thomas L. Vidmar, P.E., Deputy Director
Department of Environmental Protection
& Sustainability

TLV:jcm

c. Mike Mazurek - BCDPW